

# Modified Well Yield Testing



Site Address:

Mr. Heller

12345 Undisclosed Address

Ellicott City MD 21042

15922 A.E. Mullinix Road | Woodbine, MD 21797

410-984-1215

jeff@tpginspect.com

## Well Information

Test Date: 2-28-13

Well Tag Number: not present

Well Depth: not given

GPM at Drilling: not given

NOTES: The Well Yield Averaged 10.5 GPM

## Seconds for 5

Minute	SEC/GAL	PSI	GPM
START	<u>24</u>	<u>45</u>	12.5
15	<u>30</u>	<u>45</u>	10.0
30	<u>30</u>	<u>45</u>	10.0
45	<u>30</u>	<u>45</u>	10.0
1Hour	<u>30</u>	<u>45</u>	10.0